

Table 1: Diameter and Wall Thickness of Thermoplastic Well Casing for Standard ASTM F480

Nominal Pipe Size (inch)	Outside Diameter (inch)	Wall Thickness SDR 21 (inch)	Wall Thickness SDR 17 (inch)	Wall Thickness SDR 13.5 (inch)	Wall Thickness SCH 80 (inch)
5	5.563	0.265	0.327	0.412	0.375
6	6.625	0.316	0.390	0.491	0.432
8	8.625	0.410	0.508	--	0.500
10	10.750	--	0.632	--	--
12	12.750	--	0.750	--	--
14	14.000	--	--	--	0.750
16	16.000	--	--	--	0.843

Where schedule 80 pipe is used, the wall thickness shall be at least as thick as required in accordance with paragraph (A)(4)(c) of this rule.