

3745-91-06

Requirements for supporting information.

The supporting information required by this rule may vary depending on the type and complexity of the project and shall, at a minimum, include the following:

(A) An explanation of the project and its basis of design, and such other information relevant to approval of plans that may not be fully evident from the plan drawings and specifications;

(B) A copy of the results of any required chemical, bacteriological, radiological, or other analyses performed on the raw or finished water;

(C) A completed project summary sheet, if available.

~~(D)~~ Information as to the capacity and long-term adequacy of the source of supply; ~~and.~~

~~(E)~~ If the plans include a new well as a source of water, the following additional materials shall be submitted:

~~(1) A well site acceptance letter signed by a representative of the district office;~~

~~(2)~~ (1) A copy of a deed, easement, or other legal instrument showing that the owner has control of lands sufficient to provide isolation as approved in the well site acceptance letter; ~~and.~~

~~(3)~~ (2) A copy of the log of the well, and a copy of the results of the pumping tests performed on the well. Test pumping and sampling for chemical and radiological analyses are required unless waived by the director.

~~(F)~~ A capability assurance plan, written description of the water system's asset management program, if required by paragraph (A) of rule 3745-87-02 Chapter 3745-87 of the Administrative Code.

Effective:

Five Year Review (FYR) Dates: 4/6/2022

Certification

Date

Promulgated Under: 119.03
Statutory Authority: 6109.04
Rule Amplifies: 6109.03, 6109.04, 6109.07
Prior Effective Dates: 11/26/1980, 01/01/2002, 04/19/2012