

3745-95-08

**Violations Deny or discontinue water service.**

- (A) After reasonable notice to the occupant thereof, the supplier of water shall deny or discontinue the water service to any premises wherein any of the following occurs:
- (1) A backflow preventer required by this chapter is not installed, tested and maintained in a manner acceptable to the supplier of water.
  - (2) The backflow preventer has been removed or by-passed.
  - (3) An unprotected cross-connection exists on the premises.
  - (4) A low pressure cut-off, low suction throttling valve or variable speed suction limiting control, as required by rule 3745-95-07 of the Administrative Code, is not installed or maintained in working order.
  - (5) The supplier of water or the director, or the authorized representative of either, is denied entry to determine compliance with this chapter.
- (B) Water service to such premises shall not be restored until the consumer has corrected or eliminated such conditions or defects in conformance with this chapter , and to the satisfaction of the supplier of water.

Effective:

Five Year Review (FYR) Dates: 7/20/2022

---

Certification

---

Date

Promulgated Under: 119.03  
Statutory Authority: 6109.04  
Rule Amplifies: 6109.04, 6109.13  
Prior Effective Dates: 07/01/1972, 11/26/1980, 08/15/2018